

FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO
GE Packaged Power, Inc.

AUTHORIZING THE OPERATION OF
GE AEP APS Houston Facility
Turbine and Turbine Generator Set Units Manufacturing

LOCATED AT
Harris County, Texas
Latitude 29° 45' 30" Longitude 95° 6' 48"
Regulated Entity Number: RN100217959

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No: O1228 Issuance Date: _____

For the Commission

Table of Contents

Section	Page
General Terms and Conditions	1
Special Terms and Conditions:	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements	6
New Source Review Authorization Requirements	6
Compliance Requirements.....	7
Protection of Stratospheric Ozone	8
Permit Location	8
Permit Shield (30 TAC § 122.148)	8
Attachments	9
Applicable Requirements Summary.....	10
Additional Monitoring Requirements	20
Permit Shield	22
New Source Review Authorization References	25
Appendix A.....	30
Acronym List	31

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions:

Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:
 - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
 - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
 - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
 - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.
 - E. Emission units subject to 40 CFR Part 63, Subpart ZZZZ and HHHHHH as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter

113, Subchapter C, § 113.1090 and 113.1425 which incorporates the 40 CFR Part 63 Subpart by reference.

2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
 - A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
 - B. Title 30 TAC § 101.3 (relating to Circumvention)
 - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
 - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
 - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
 - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
 - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
 - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
 - I. Title 30 TAC § 101.222 (relating to Demonstrations)
 - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
 - A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity averaged over a six-minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:
 - (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
 - (ii) Title 30 TAC § 111.111(a)(1)(E)
 - (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
 - (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that

does not obstruct the transmission of light. Vents, as specified in the “Applicable Requirements Summary” attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:

- (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
- (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
- (3) Records of all observations shall be maintained.
- (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (5) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is

determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from a building, enclosed facility, or other structure; the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(7)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(7)(B)(i) or (ii)
- (iii) For a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source subject to 30 TAC § 111.111(a)(7)(A), complying with 30 TAC § 111.111(a)(7)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
 - (1) An observation of visible emissions from a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source which is required to comply with 30 TAC § 111.111(a)(7)(A) shall be conducted at least once during each calendar quarter unless the air emission source or enclosed facility is not operating for the entire quarter.
 - (2) Records of all observations shall be maintained.
 - (3) Visible emissions observations of air emission sources or enclosed facilities operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of air emission sources or enclosed facilities operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each emissions outlet in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each emissions outlet during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

- (4) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(7) and (a)(7)(A)
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(7)(B) to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
- C. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.
- D. Outdoor burning, as stated in 30 TAC § 111.201, shall not be authorized unless the following requirements are satisfied:
 - (i) Title 30 TAC § 111.207 (relating to Exception for Recreation, Ceremony, Cooking, and Warmth)
 - (ii) Title 30 TAC § 111.219 (relating to General Requirements for Allowable Outdoor Burning)
 - (iii) Title 30 TAC § 111.221 (relating to Responsibility for Consequences of Outdoor Burning)
- 4. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:
 - A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
 - B. Title 40 CFR § 60.8 (relating to Performance Tests)
 - C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
 - D. Title 40 CFR § 60.12 (relating to Circumvention)
 - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
 - F. Title 40 CFR § 60.14 (relating to Modification)
 - G. Title 40 CFR § 60.15 (relating to Reconstruction)

- H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
5. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.
6. The permit holder shall comply with certified registrations submitted to the TCEQ for purposes of establishing federally enforceable emission limits. A copy of the certified registration shall be maintained with the permit. Records sufficient to demonstrate compliance with the established limits shall be maintained. The certified registration and records demonstrating compliance shall be provided, on request, to representatives of the appropriate TCEQ regional office and any local air pollution control agency having jurisdiction over the site. The permit holder shall submit updated certified registrations when changes at the site require establishment of new emission limits. If changes result in emissions that do not remain below major source thresholds, the permit holder shall submit a revision application to codify the appropriate requirements in the permit.

Additional Monitoring Requirements

7. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time or minimum frequency specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

New Source Review Authorization Requirements

8. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule, standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
- A. Are incorporated by reference into this permit as applicable requirements
 - B. Shall be located with this operating permit
 - C. Are not eligible for a permit shield
9. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
10. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of

operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).

Compliance Requirements

11. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
12. Use of Emission Credits to comply with applicable requirements:
 - A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) Offsets for Title 30 TAC Chapter 116
 - B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)-(d)
 - (ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1
 - (iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)-(d)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.305 (relating to Emission Reductions Achieved Outside the United States)
13. Use of Discrete Emission Credits to comply with the applicable requirements:
 - A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117

- (iii) If applicable, offsets for Title 30 TAC Chapter 116
 - (iv) Temporarily exceed state NSR permit allowables
- B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
 - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
 - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

Protection of Stratospheric Ozone

- 14. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:
 - A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.

Permit Location

- 15. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

Permit Shield (30 TAC § 122.148)

- 16. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

Attachments

Applicable Requirements Summary

Additional Monitoring Requirements

Permit Shield

New Source Review Authorization References

Applicable Requirements Summary

Unit Summary	11
---------------------------	-----------

Applicable Requirements Summary	13
--	-----------

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
AUX-2	SRIC ENGINES	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
COMP-2	SRIC ENGINES	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
COMP-3	SRIC ENGINES	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
FIREPUMP-1	SRIC ENGINES	N/A	R7ICI-1	30 TAC Chapter 117, Subchapter B	No changing attributes.
FIREPUMP-1	SRIC ENGINES	N/A	60IIII-1	40 CFR Part 60, Subpart IIII	No changing attributes.
FIREPUMP-1	SRIC ENGINES	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
FLARE-2	FLARES	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRPOWS	VOLATILE ORGANIC COMPOUND WATER SEPARATORS	OWS-1, OWS-2, OWS-3	R5131-1	30 TAC Chapter 115, Water Separation	No changing attributes.
GRPSTACK	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	CLTEST-1, DT-1, DT-2, TEST-1	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRPTANK2	STORAGE TANKS/VESSELS	HTH-1, HTH-3, HTK- 1, J-WWT1, T-160, T-170	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPTANK3	STORAGE TANKS/VESSELS	VTW-1, VTW-2, VTW-4, WWT-1, WWTH-3	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPTANK4	STORAGE TANKS/VESSELS	VTH-2	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPTANK5	STORAGE TANKS/VESSELS	WWT-2, WWT-3	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
PROCLEAN	CLEANING/DEPAINTING OPERATION	N/A	R5461-1	30 TAC Chapter 115, Subchapter E, Division 6	No changing attributes.
PROPAINT	SURFACE COATING OPERATIONS	N/A	63HHHHHH-PB	40 CFR Part 63, Subpart HHHHHH	No changing attributes.
T-180	STORAGE TANKS/VESSELS	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
WWT-L	LOADING/UNLOADING OPERATIONS	N/A	R5211-1	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
AUX-2	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii	§ 63.6625(i) § 63.6655(d) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
COMP-2	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table2d.12 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6640(b) § 63.6640(c)(7)	For each existing non-emergency, non-black start 4SRB stationary RICE with a site rating greater than 500 HP that is not a remote stationary RICE and that operates more than 24 hours per calendar year, you must install NSCR to reduce HAP emissions from the stationary RICE.	§ 63.6612(a) [G]§ 63.6612(b) § 63.6620(a) § 63.6620(a)-Table4.1.a.i § 63.6620(a)-Table4.1.a.ii § 63.6620(a)-Table4.1.a.iii § 63.6620(b) § 63.6620(d) § 63.6620(e)(1) [G]§ 63.6620(e)(2) [G]§ 63.6625(b) § 63.6630(a)-Table5.14.a.i § 63.6630(a)-Table5.14.a.ii § 63.6630(e) § 63.6630(e)(1) § 63.6630(e)(2) § 63.6630(e)(3) § 63.6630(e)(5) § 63.6630(e)(6) § 63.6635(a) § 63.6635(b) § 63.6640(a) § 63.6640(a)-Table6.15.a.i § 63.6640(a)-Table6.15.a.ii	§ 63.6635(a) § 63.6635(c) § 63.6655(a) § 63.6655(a)(1) § 63.6655(a)(2) § 63.6655(a)(3) § 63.6655(a)(4) § 63.6655(a)(5) [G]§ 63.6655(b) § 63.6655(d) § 63.6655(e) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(b) § 63.6640(e) § 63.6645(a) § 63.6645(g) § 63.6645(h) § 63.6650(a) § 63.6650(a)-Table7.3 § 63.6650(b) § 63.6650(b)(1) § 63.6650(b)(2) § 63.6650(b)(3) § 63.6650(b)(4) [G]§ 63.6650(c) [G]§ 63.6650(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.6640(b) § 63.6640(c) § 63.6640(c)(1) § 63.6640(c)(2) § 63.6640(c)(3) § 63.6640(c)(5) § 63.6640(c)(6) § 63.6640(c)(7)		
COMP-3	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)- Table2d.12 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6640(b) § 63.6640(c)(7)	For each existing non-emergency, non-black start 4SRB stationary RICE with a site rating greater than 500 HP that is not a remote stationary RICE and that operates more than 24 hours per calendar year, you must install NSCR to reduce HAP emissions from the stationary RICE.	§ 63.6612(a) [G]§ 63.6612(b) § 63.6620(a) § 63.6620(a)- Table4.1.a.i § 63.6620(a)- Table4.1.a.ii § 63.6620(a)- Table4.1.a.iii § 63.6620(b) § 63.6620(d) § 63.6620(e)(1) [G]§ 63.6620(e)(2) [G]§ 63.6625(b) § 63.6630(a)- Table5.14.a.i § 63.6630(a)- Table5.14.a.ii § 63.6630(e) § 63.6630(e)(1) § 63.6630(e)(2) § 63.6630(e)(3) § 63.6630(e)(5) § 63.6630(e)(6) § 63.6635(a) § 63.6635(b) § 63.6640(a) § 63.6640(a)- Table6.15.a.i § 63.6640(a)- Table6.15.a.ii	§ 63.6635(a) § 63.6635(c) § 63.6655(a) § 63.6655(a)(1) § 63.6655(a)(2) § 63.6655(a)(3) § 63.6655(a)(4) § 63.6655(a)(5) [G]§ 63.6655(b) § 63.6655(d) § 63.6655(e) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(b) § 63.6640(e) § 63.6645(a) § 63.6645(g) § 63.6645(h) § 63.6650(a) § 63.6650(a)-Table7.3 § 63.6650(b) § 63.6650(b)(1) § 63.6650(b)(2) § 63.6650(b)(3) § 63.6650(b)(4) [G]§ 63.6650(c) [G]§ 63.6650(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.6640(b) § 63.6640(c) § 63.6640(c)(1) § 63.6640(c)(2) § 63.6640(c)(3) § 63.6640(c)(5) § 63.6640(c)(6) § 63.6640(c)(7)		
FIREPUMP-1	EU	R7ICI-1	Exempt	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
FIREPUMP-1	EU	60III-1	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 560 KW and a displacement of less than 30 liters per cylinder and is a 2009 model year and later must comply with an NMHC+NO _x emission limit	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						of 4.0 g/KW-hr, as listed in Table 4 to this subpart.			
FIREPUMP-1	EU	60III-1	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 560 KW and a displacement of less than 30 liters per cylinder and is a 2009 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as listed in Table 4 to this subpart.	None	None	[G]§ 60.4214(d)
FIREPUMP-1	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
FLARE-2	EU	R1111-1	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period, except for upset emissions as provided in	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						§101.222(b).			
GRPOWS	EU	R5131-1	VOC	30 TAC Chapter 115, Water Separation	§ 115.137(a)(2) [G]§ 115.132(a)(4)	Any single or multiple compartment VOC water separator which separates materials having a true vapor pressure of VOC < .5 psia obtained from any equipment is exempt from §115.132(a).	[G]§ 115.135(a) § 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	None
GRPSTACK	EP	R1111-1	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRPTANK2	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
GRPTANK3	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
GRPTANK4	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
GRPTANK5	EU	R5112-1	VOC	30 TAC Chapter	§ 115.111(a)(1)	Except as provided in §	[G]§ 115.117	§ 115.118(a)(1)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				115, Storage of VOCs		115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.		§ 115.118(a)(5) § 115.118(a)(7)	
PROCLEAN	PRO	R5461-1	VOC	30 TAC Chapter 115, Subchapter E, Division 6	§ 115.461(a) [G]§ 115.463(d)	Solvent cleaning operations located on a property with total actual volatile organic compounds (VOC) emissions of less than 3.0 tons per calendar year from all cleaning solvents, when uncontrolled, are exempt from the requirements of this division, except as specified in §115.468(b)(2) of this title. When calculating the VOC emissions, solvents used for cleaning operations that are exempt from this division under subsections (b)-(e) of this section are excluded.	None	§ 115.468(b)(2) § 115.468(b)(5)	None
PROPAINT	PRO	63HHHHH H-PB	112(B) HAPS	40 CFR Part 63, Subpart HHHHHH	[G]§ 63.11173(e) [G]§ 63.11173(f) [G]§ 63.11173(g)	Each motor vehicle and mobile equipment surface coating operation and each miscellaneous surface coating operation must meet the requirements in paragraphs (e)(1) through (e)(5) of this section.	§ 63.11173(e)(2)(i) § 63.11173(e)(3)	§ 63.11173(f) § 63.11173(f)(1) § 63.11173(f)(3) § 63.11177 § 63.11177(a) § 63.11177(b) § 63.11177(c) § 63.11177(d) § 63.11177(g) § 63.11177(h) § 63.11178(a)	[G]§ 63.11175(a) [G]§ 63.11175(b) [G]§ 63.11176(a)
T-180	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						psia is exempt from the requirements of this division.			
WWT-L	EU	R5211-1	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None

Additional Monitoring Requirements

Periodic Monitoring Summary 21

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPSTACK	
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: If an alternate fuel is used it shall be considered and reported as a deviation.	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, for a period greater than or equal to 24 consecutive hours it shall be considered and reported as a deviation or the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are observed. Any time an alternate fuel is fired for a period of greater than 7 consecutive days then visible emissions observations will be conducted no less than once per week. Documentation of all observations shall be maintained. If visible emissions are present during the firing of an alternate fuel, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

Permit Shield

Permit Shield 23

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
AUX-1	N/A	30 TAC Chapter 115, Vent Gas Controls	Combustion units that are not control devices are exempt from this regulation
AUX-1	N/A	30 TAC Chapter 117, Subchapter B	These engines are used for testing and starting turbines.
AUX-2	N/A	30 TAC Chapter 115, Vent Gas Controls	Combustion units that are not control devices are exempt from this regulation
AUX-2	N/A	30 TAC Chapter 117, Subchapter B	These engines are used for testing and starting turbines.
COMP-1	N/A	30 TAC Chapter 115, Vent Gas Controls	Combustion units that are not control devices are exempt from this regulation.
COMP-1	N/A	30 TAC Chapter 117, Subchapter B	These engines are used for testing and starting turbines,
COMP-2	N/A	30 TAC Chapter 117, Subchapter B	These engines are used for testing and starting turbines.
COMP-2	N/A	40 CFR Part 60, Subpart JJJJ	The commence construction date for this unit is 1-12-2006. The applicability date for owners and operators is 6-12-2006.
COMP-3	N/A	30 TAC Chapter 117, Subchapter B	These engines are used for testing and starting turbines.
COMP-3	N/A	40 CFR Part 60, Subpart JJJJ	The commence construction date for this unit is 1-12-2006. The applicability date for owners and operators is 6-12-2006.
EVAP-1	N/A	30 TAC Chapter 117, Subchapter B	Process heater has a maximum rated capacity less than 2.0 MMBtu/hr.
FLARE-2	N/A	40 CFR Part 60, Subpart A	Flare is not used to comply with any 40 CFR

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
			Part 60 or Part 61 subparts.
FLARE-2	N/A	40 CFR Part 63, Subpart A	The flare is not required by a Subpart under 40 CFR Part 63.
GRPSTACK	CLTEST-1, DT-1, DT-2, TEST-1	30 TAC Chapter 115, Vent Gas Controls	Combustion units that are not control devices are exempt from this regulation.
GRPSTACK	CLTEST-1, DT-1, DT-2, TEST-1	30 TAC Chapter 117, Utility Electric Division 2	The turbines tested in these units are not "stationary gas turbines", as defined by this regulation, since they are not operated at a specific source for more than 90 days in a 12-month period.
GRPSTACK	CLTEST-1, DT-1, DT-2, TEST-1	40 CFR Part 60, Subpart GG	Does not meet the definition of an affected stationary gas turbine.
GRPTANK1	HTW-3, WWTH-1, WWTH-2	30 TAC Chapter 115, Storage of VOCs	The maximum storage capacities of these tanks are less than 1,000 gallons.
HW1	N/A	30 TAC Chapter 117, Subchapter B	Process heater has a maximum rated capacity less than 2.0 MMBtu/hr.
HW2	N/A	30 TAC Chapter 117, Subchapter B	Process heater has a maximum rated capacity less than 2.0 MMBtu/hr.
PROPAINT	N/A	40 CFR Part 63, Subpart Mmmm	The site is not a major source of HAPs.

New Source Review Authorization References

New Source Review Authorization References	26
New Source Review Authorization References by Emission Unit	28

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 17692	Issuance Date: 11/19/2014
Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 106.183	Version No./Date: 06/18/1997
Number: 106.183	Version No./Date: 09/04/2000
Number: 106.227	Version No./Date: 03/14/1997
Number: 106.242	Version No./Date: 09/04/2000
Number: 106.244	Version No./Date: 03/14/1997
Number: 106.261	Version No./Date: 11/01/2003
Number: 106.262	Version No./Date: 12/24/1998
Number: 106.263	Version No./Date: 03/14/1997
Number: 106.263	Version No./Date: 09/04/2000
Number: 106.264	Version No./Date: 03/14/1997
Number: 106.264	Version No./Date: 09/04/2000
Number: 106.265	Version No./Date: 03/14/1997
Number: 106.265	Version No./Date: 09/04/2000
Number: 106.266	Version No./Date: 03/14/1997
Number: 106.266	Version No./Date: 09/04/2000
Number: 106.313	Version No./Date: 03/14/1997
Number: 106.316	Version No./Date: 03/14/1997
Number: 106.317	Version No./Date: 03/14/1997
Number: 106.320	Version No./Date: 09/04/2000
Number: 106.371	Version No./Date: 03/14/1997
Number: 106.372	Version No./Date: 03/14/1997
Number: 106.451	Version No./Date: 03/14/1997
Number: 106.452	Version No./Date: 03/14/1997
Number: 106.454	Version No./Date: 07/08/1998
Number: 106.472	Version No./Date: 03/14/1997
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.473	Version No./Date: 03/14/1997
Number: 106.473	Version No./Date: 09/04/2000
Number: 106.478	Version No./Date: 03/14/1997

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Number: 106.492	Version No./Date: 09/04/2000
Number: 106.511	Version No./Date: 03/14/1997
Number: 106.512	Version No./Date: 03/14/1997
Number: 106.512	Version No./Date: 06/13/2001
Number: 106.531	Version No./Date: 03/14/1997
Number: 106.532	Version No./Date: 03/14/1997
Number: 106.532	Version No./Date: 09/04/2000
Number: 106.102	Version No./Date: 11/15/1996
Number: 106.532	Version No./Date: 03/14/1997

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
AUX-1	DYNATEST AUXILIARY DIESEL GENERATOR	17692
AUX-2	TESTLINE AUXILIARY DIESEL GENERATOR	17692
CLTEST-1	CLOSED LOOP TEST CELL	17692
COMP-1	TESTLINE COMPRESSOR	17692
COMP-2	FUEL GAS COMPRESSOR	106.512/06/13/2001
COMP-3	FUEL GAS COMPRESSOR	106.512/06/13/2001
DT-1	DYNATEST	17692
DT-2	DYNATEST	17692
EVAP-1	EVAPORATOR 1	106.183/09/04/2000
FIREPUMP-1	DIESEL FIRE PUMP	106.512/06/13/2001
FLARE-2	FLARE 2	106.492/09/04/2000
HTH-1	TESTLINE STORAGE TANK	106.472/03/14/1997
HTH-3	TESTLINE STORAGE TANK	106.472/03/14/1997
HTK-1	DYNATEST STORAGE TANK	106.472/03/14/1997
HTW-3	EVAPORATOR TANK	106.472/03/14/1997
HW1	HOT WASH HEATER 1	106.183/09/04/2000
HW2	HOT WASH HEATER 2	106.183/09/04/2000
J-WWT1	BUILDING J STORAGE TANK	106.472/03/14/1997
OWS-1	OIL/WATER SEPARATOR	106.532/03/14/1997
OWS-2	OIL/WATER SEPARATOR	106.532/03/14/1997
OWS-3	COLLECTION SUMP/SEPARATOR	106.532/03/14/1997

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
PROPAINT	PROPAINT	17692
T-160	TESTPAD STORAGE TANK	106.473/03/14/1997
T-170	TESTPAD STORAGE TANK	106.473/03/14/1997
T-180	TESTPAD STORAGE TANK T-180	106.473/09/04/2000
TEST-1	TURBINE TESTLINE	17692
VTH-2	TESTLINE STORAGE TANK	106.472/03/14/1997
VTW-1	EVAPORATOR SURGE TANK	106.472/03/14/1997
VTW-2	EVAPORATOR SURGE TANK	106.472/03/14/1997
VTW-4	EVAPORATOR BOTTOMS TANK	106.472/03/14/1997
WWT-1	WASTEWATER STORAGE TANK	106.472/03/14/1997
WWT-2	WASTEWATER STORAGE TANK	106.472/03/14/1997
WWT-3	WASTEWATER STORAGE TANK	106.472/03/14/1997
WWTH-1	RECYCLE TANK	106.472/03/14/1997
WWTH-2	RECYCLE TANK	106.472/03/14/1997
WWTH-3	STORAGE TANK	106.472/03/14/1997
WWT-L	WASTEWATER TRUCK LOADING	106.472/03/14/1997

Appendix A

Acronym List 31

Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
CEMS	continuous emissions monitoring system
CFR	Code of Federal Regulations
COMS	continuous opacity monitoring system
CVS	closed vent system
D/FW	Dallas/Fort Worth (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H ₂ S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MACT	Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr	Million British thermal units per hour
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NESHAP	National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO _x	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PEMS	predictive emissions monitoring system
PM	particulate matter
ppmv	parts per million by volume
PRO	process unit
PSD	prevention of significant deterioration
psia	pounds per square inch absolute
SIP	state implementation plan
SO ₂	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound